

**FITNESS CERTIFICATE FOR SCHOOL BUILDING FOR 2023-24**

Name of Officer : Indushree I B  
Name of School : St. Xavier's Public School, Kandakadavu  
Location with name of Ednl Distr : Ernakulam, Mattancherry  
Classification of buildings : (1) Main Building:  
GF 52.30\*6.90\*3.70 & 15.30\*8.70\*3.70 (4 Class rooms, 1 Office room, 1 Staff Room)  
FF 52.30\*6.90\*3.70 & 15.30\*8.70\*3.70 (8 Class rooms)  
SF: 52.30\*6.90\*3.70 & 15.30\*8.70\*3.70 (8 Class rooms)  
(2) Additional Building.  
GF 31.60\*9.25\*3.70 (4 Class rooms)  
FF 31.60\*9.25\*3.70 (4 Class rooms)

Period for which the certificate is issued : 2023-24

Nature of defects if any,

a) Foundation and basement : NIL

b) Superstructure : Minute hairline cracks on beam wall junction and column wall junction of Additional Building.

c) Door windows : NIL

d) Wood work wrought and put up : NIL

e) Roof : NIL

f) Flooring : NIL

g) Miscellaneous : NIL

Any major defects noticed which will Render the building unsafe in any manner : No

Whether maintenance work have been done properly : Yes

Whether the structure is sound or not for conducting classes : Structure is sound under normal weather Condition.

Certified that the school was inspected by me on 29/05/2023 and found to be fit to conduct classes for the period up to 31<sup>st</sup> March 2024 for the reason stated above.

Place: Chellanam

Date: 29/05/2023



Indushree  
ASSISTANT ENGINEER,  
L.S.G.D. SECTION  
Chellanam